



SUTTER COUNTY

DEVELOPMENT SERVICES DEPARTMENT

Building Inspection
Code Enforcement

Engineering/Water Resources
Environmental Health/CUPA

Planning
Road Maintenance

UNDERGROUND STORAGE TANK APPLICATION FOR PERMIT TO REMOVE

Facility:		Owner:			
Address:		Address:			
Phone:		Phone:			
Contractor:		Analytical Lab:			
Address:		Address:			
Phone:		Phone:			
	Tank 1	Tank 2	Tank 3	Tank 4	
Size of Tanks					
Contents					
REMOVAL REQUIREMENTS					
1. All residual liquid, solids, and/or sludge shall be removed and handled as a hazardous waste or recyclable material in accordance with 6.5 of the Health and Safety Code.					
2. Tanks shall be made inert prior to excavation and removal to below 10% LEL using dry ice at a rate of 30 lbs per 1,000 gallons.					
3. Associated piping must be flushed, excavated, removed, and properly disposed of, unless deemed unfeasible by the CUPA. If unfeasible, piping must be capped.					
4. Sampling must be conducted according to sampling requirements.					
5. All site work must be in accordance with OSHA standards and safe business practices.					
TANK DISPOSAL OPTIONS (Designate one)					
<input type="checkbox"/> TREATMENT, STORAGE, AND/OR DISPOSAL FACILITY (TDSF) – Tanks shall be manifested and hauled by a licensed hauler to an EPA permitted TDSF. A copy of the manifest must be submitted within 30 days.			<input type="checkbox"/> SPECIFIC REUSE – Tanks are destined for a specific reuse which must be designated by the owner of the tank. Reuse does not allow for cutting of the tank, or otherwise compromising the integrity of the tank. If tanks are not in good condition upon removal, reuse will not be allowed and disposal at a TDSF must be made within 5 days.		
Hauler:		New Owner:			
Hauler EPA#:					
Address:		Address:			
Phone:		Phone:			
Designated TDSF:		Nature of Reuse:			
Address					
Phone:					
NOTE: Fire Departments may require removal permit in addition to the County permit.					

SAMPLING REQUIREMENTS

A minimum of two soil samples per tank, and at least one for each 20 linear feet of piping, must be obtained under the direction of the removal inspector. If water is present, water samples may be required. Additional samples may be required.

Soil samples are to be analyzed by a State-approved lab for contents of the tank and breakdown products. Other analysis may be required.

Proper sampling techniques and containers are to be used, and containers properly sealed. Samples are to be transported under proper chain-of-custody.

A copy of all sample results shall be submitted to the Sutter County Environmental Health Division – CUPA within 30 days.

Minimum Verification Analysis	Method
Total Petroleum Hydrocarbons - Gasoline	GCFID(5030), GCMS 8260
Total Petroleum Hydrocarbons - Diesel	GCFID(3550), GCMS 8260
Benzene, Toluene, Xylene, Ethylbenzene	GCPID 8021. GCMS 8260
Solvents	GCEC/PID; GC8021
MTBE, TBA, DIPE, ETBE, TAME, Ethanol, Methanol, 1,2 DCA, EDB	GCMS 8260
Oil and Grease	1664A
Metals	610AA or ICAP
Pesticides/Creosote	8081A PCB*PCP*PNA / GCMS8021

REPORTING REQUIREMENTS

If the results of the soil sample analysis and/or other criteria, such as site conditions, indicate an unauthorized release, an Underground Storage Tank Unauthorized Release (Leak)/Contamination Site Report shall be filed within 5 days by the tank owner. Forms may be obtained from the CUPA.

Site investigation and cleanup shall be according to Article 11 of the Underground Storage Tank Regulations, and the Tri-regional Guidelines. Oversight agencies shall be the Sutter County Environmental Health Division and the Regional Water Quality Control Board. Workplans shall be approved prior to any work.

A fee may be charged for cleanup oversight by the CUPA.

OWNER DECLARATION

I declare, under penalty of perjury, under the laws of the State of California, that I have read, and I understand, and agree to adhere to the requirements of this application to remove underground storage tanks. Furthermore, I will carry out the actions and abide by the provisions as indicated.

Owner Signature:

Print Names:

Date: