



# SUTTER COUNTY

## DEVELOPMENT SERVICES DEPARTMENT

Building Inspection  
Code Enforcement

Engineering/Water Resources  
Environmental Health

Planning  
Road Maintenance

---

### **UNDERGROUND STORAGE TANK PROGRAM**

#### **REPAIR/MODIFICATION/UPGRADE CLASSIFICATIONS**

#### **Work Requiring a Repair/Modification/Upgrade Permit**

This work includes any type of repair/modification/upgrade that will require the following:

- > Piping upgrades
- > Any piping repairs
- > Lining repairs/installations/inspections
- > Tank shell repairs
- > Sump replacements
- > Under-Dispenser Containment replacements
- > Replacement of a direct-bury spill container
- > Installation of a new monitoring system or console
- > Replacement of any monitoring equipment with a “non-like” item
- > Repair/replacement of Cathodic protection equipment
- > Installation of new overfill prevention system
- > Replacing a drop tube

#### **Work Not Requiring a Permit but Requiring Submittal of Description of Repair Work Completed**

The following repairs/modifications do not require a permit from Sutter County Environmental Health. However, any repairs completed require the submittal of the “Description of Repair Work Completed” form:

- > Replacing a spill container that is contained in a sump
- > Replacing sensors “like for like”
- > Replacing an automatic line leak detector “like for like”
- > Repairing/replacing test boots
- > Replacing a turbine “like for like”
- > Installation of new dispensers (without any work being done below the shear valve)

P:\UST\FORMS\UST Repair Modification Upgrade Classifications-Aug2021.doc